

AnnexureC

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Dated: 15.07.2026

It is certified that an inspection team headed by Shivam Kumar, Assistant Engineer, (Name of Officers with designation) from UP JAL NIGAM (RURAL) HAMIRPUR (Name of the Department/Office) inspected the Taj Public School, Fattepur, Maudaha, Hamirpur -210507 District Hamirpur,UP-210301. (Name & Address of the school) on 13.07.2026 (date of inspection),and on the basis Water Test Report (Attached) dated: 15.07.2026 District level Water Analysis Laboratory, UP Jal Nigam (Rural) certified that the Taj Public School, Fattepur, Maudaha, Hamirpur -210507 has safe drinking water facilities for the students and members of staff of the institution. School is also maintain the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central /State/U.T. Govt.

The above is valid for a period of 2026-2027.

सहायक अभियन्ता

Signature with Seal: उ० प्र० जल निगम(ग्रामीण)

Name: Shivam Kumar हमीरपुर

Designation: Assistant Engineer.

Assistant Engineer of the
Govt. Public Health Department
(PHED)/

Authorised Officer of the Local Body

Name & Address of the Office/

Department: UP JAL NIGAM (RURAL),
HAMIRPUR.

To
TAJ PUBLIC SCHOOL
Fattepur, Maudaha,
Hamirpur - 210507



Analysis Report level Water Analysis Laboratory, U.P. Jal Nigam (Rural), Bhilawan, Hamirpur

Report No:-42		URL No. TC 138132600000042F		Date:- 15.07.2026		Page No:- 1/1	
Office Name and Date		Customer Details					
Ref. Letter No & Date		Taj Public School, Fattepur, Maudaha, Hamirpur- 210507					
Sampling Method		ISO 17614 (Part-1) : 2021					
District		Hamirpur		Basic Details of Sample		Maudaha	
Gram Panchayat		Fattepur		Block		Fattepur	
Habitation				Village		Fattepur	
Water Source		Ground Water		Location		Fattepur	
Quantity of Sample		1000 ml		Sample Code		H/26/07/4583	
Sample Receiving Date		13.07.2026		Date of Sample Collection		13.07.2026	
Sample Depositor		Himanshu		Sample Collector		Rajendra	
Analysis start Date		14.07.2026		Analysis Completion Date		15.07.2026	
Temperature		25±3 °C		Environmental Condition		Relative Humidity	
						50±15 %	
Technical Data of Analysis							
Sr. No.	Analysed Parameters	Units	Observed value	Specified values as per BIS		Ref. Method of Analysis	
				Acceptable Limit	Permissible Limit		
1	Taste		Not agreeable	Agreeable/ Not agreeable	Agreeable/ Not agreeable	IS 3025 (Part 8):2017	
2	Odour	-	Not agreeable	Agreeable/ Not agreeable	Agreeable/ Not agreeable	IS 3025 (Part 5):2018	
3	Colour	HU	10	5	15	IS 3025 (Part 4):2017 (Platinum Cobalt Visual Comparison Method)	
4	Turbidity	NTU	2.10	1	5	IS 3025 (Part 10):2017 (Nephelometric Method)	
5	pH	-	7.85	6.5-8.5	No Relaxation	IS 3025 (Part 11):2017	
6	TDS	(mg/L)	414	500	2000	IS 3025 (Part 16):2017 (Gravimetric Method)	
7	Chloride	(mg/L)	118	250	1000	IS 3025 (Part 32):2019 (Argentometric Method)	
8	Fluoride	(mg/L)	0.762	1	1.5	APHA 23rd EDITION-4500-F Method E (Electrode Method):20	
9	Total Alkalinity	(mg/L)	120	200	600	IS 3025 (Part 23):2019	
10	Calcium	(mg/L)	64	75	200	IS 3025 (Part 40):2019 (EDTA Method)	
11	Magnesium	(mg/L)	28.96	30	100	IS 3025 (Part 46):2019	
12	Total Hardness	(mg/L)	220	200	600	IS 3025 (Part 21):2019 (EDTA Method)	
13	Iron	(mg/L)	0.61	1.0	No Relaxation	APHA 24 Edition 3500-Fe Method B (Phenanthroline Method):2023	
14	Sulphate	(mg/L)	44.12	200	400	APHA 24 Edition 4500-SO4 Method E (Turbidimetric Method):2023	
15	Nitrate	(mg/L)	19.72	45	No Relaxation	APHA 24 Edition 4500-SO4 Method B (Turbidimetric Method):2023	

- Note-**
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from head of Laboratory.
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 07 day (In case of non perishable items only) from the date of issue of tests reports.

Himanshu
(Himanshu Soni)
Lab technician
Prepared By

Poonam
Review of Report
(Poonam Devi)
Lab Assistant



*** End of the Report ***



**District Level Water Analysis Laboratory,
Uttar Pradesh Jal Nigam (Rural)
Hamirpur.**

Address: Bhilawan (Near Yamuna Side), District-Hamirpur, Pincode-210301

BACTERIOLOGICAL SAMPLE TEST REPORT

Rept. No 1	Date: 15.07.2026		Page No	1/1		
Customer Details						
Office Name and Address	Taj Public School, Fattepur, Maudaha, Hamirpur - 210507					
Ref Letter No & Date						
Basic details of sample						
District	Hamirpur	Block	Maudaha			
Gram Panchayat		Village	Fattepur			
Habitation	-	Location	Fattepur			
Water Source	Ground Water	Sample Code	H/26/07/4695			
Quantity of Sample	1000 ml	Date of S.C.	13.07.2026			
Receiving Date	13.07.2026	S. Collector	Rajendra			
Sample Depositor	Rajendra					
Analysis Start Date	14.07.2026	Analysis Completion Date	15.07.2026			
Technical Data of Analysis						
Sr. No	Analyzed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Ph	7.85		6.5-8.5	No relaxation	IS 3025 (Part11):2017
2	Residual Chlorine	0.0	mg/L	0.2	1.0	IS 3025 (PART26):1986
3	Total Coliform	0.0	CFU		CFU	APHA23 rd Edition :2017
4	E. Coli	0.0	CFU		CFU	APHA23 rd Edition :2017
Result :		Remark:				
Note.						
1. This Certificate refers only to the particular sample(s) submitted for testing.						
2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from head of Laboratory.						
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.						
4. Sample will be stored up to 07 day (in case of non perishable items only) from the date of Issue of tests reports.						
Himanshu (Himanshu Soni) Lab technician Prepared By Authorized Signatory						

End of the Report